

تاریخ: ۱۴۰۲/۷/۱۳
شماره: ۱۱۸۸-الف/۲-م-س-ک
پیوست: ندارد

بیمارستان فوق تخصصی آیت الله یثربی (ع)



Dear CEO and Representative of DP Iran,

Hello,

Respectfully attached is the report on the cultivation of environmental and airborne particles in the isolated VIP patient rooms after the air purification devices from your company were turned off due to the expiration of the filter usage time. The attached report shows an increase in microbial pollution, especially in isolation, which leads to secondary infections in patients. Therefore, please instruct to replace the filters as soon as possible.

دکتر مصطفی سروی زاده
رئیس بیمارستان



تدقیق و تصدیق
سازمان غذا و دارو
مجلس تخصصی
بیماریهای عفونی



تدقیق و تصدیق
سازمان غذا و دارو
مجلس تخصصی
بیماریهای عفونی



نشان عالی مدیریت
در بخش اعصاب
سازمان غذا و دارو
مدیر عالی



ISO
9001:2015
45001:2018
14001:2015
22420:1396



IPD



۵۵۹۰
۵۵۶۲۱۵۲۰
www.yasrebihospital.ir
info@yasrebihospital.ir

آدرس: کاشان، بلوار قطب راوندی، بلوار پرستار
کد پستی: ۸۷۱۵۹-۷۳۲۵۴